



Czech

TYPE CERTIFICATE

Registration Number **01.961.825/10/07/02/0**

issued for the manufacturer:

DEXON CZECH s.r.o.
Na Novém poli 381/5
CZ - 733 01 Karviná – Staré Město
Identification number: 25899783

for the product:

Name: **Loudspeaker for installation in ceilings and soffits for emergency sound systems**

Type designation: **RPT XX3**

Modification: RPT 83, RPT 93, RPT 103

Manufacturer: **DEXON CZECH s.r.o., Na Novém poli 381/5**
733 01 Karviná – Staré Město

At which the certification in accordance with the certification schema Instruction ISO/IEC 67 – System 3 according to the certification system of TÜV SÜD Czech which results are stated in the Evaluation report no 904/70/10/BT/IZ/E from 22th June 2010.

The product type mentioned above fulfils the applicable requirements of following regulations/standards which was the basis for its evaluation: ČSN EN 60065:2003 +A1:06+A11:09 (idt EN 60065:2002+A1:06+A11:08), ČSN EN 60849:1999 (idt EN 60849:1998), ČSN EN 55103-1:1998 (idt EN 55103-1:1996), ČSN EN 50130-4:1997+A1:99+A2:03 (idt EN 50130-4:1995+A1:98+A2:03), ČSN EN 61000-3-2 ed.3:2006+A1:10+A2:10 (idt EN 61000-3-2:2006+A1:09+A2:09), ČSN EN 61000-3-3 ed.2:2009 (idt EN 61000-3-3:2008)

This certificate is valid till: 08th July 2015

Details and validity conditions are stated in the annex which forms an integral part of this Certificate and contains 1 page.

Prague, 08th July 2010



Head of the certification body

1. The product specimen was entered for evaluation on 13th May 2010.
2. The Certificate was issued on the basis of documents provided by the client: Purchase order from 01st April 2010, application for the certifying from 13th May 2010, undermentioned producing and accompanying technical documentation.
3. The Quality System audit was performed at the product manufacturer concentrating on elements ensuring the continuation of product conformity with certification requirements. The results are given in the Evaluation Report no.0277/70/04/BT/IZ/E from 16th February 2004 (order no. 700/70/2003) and in the Record of supervision of the manufacturing site from 13th May 2010 (order no. 428/70/2010).
4. Detailed technical data characterizing the product type:

Modification:	RPT 83	RPT 93	RPT 103
Voltage:	100 V (primary circuit of the transformer)		
Frequency:	50 Hz ÷ 15000 Hz	110 Hz ÷ 13000 Hz	60 Hz ÷ 15000 Hz
Input power:	1,5 W, 3 W, 6 W	10/100 V, 20 W max	2,5 W, 5 W, 10 W
Transformer:	TF 00015	P/N:001-40010-10	TF 00015
Impedance of loudspeaker		8 Ω	
Thermal in fuse:	135 °C	130 °C (In= 2A, Un=250 V AC),	135°C
Protective class:		I	

5. The list of important parts of the technical documentation:
 - The documentation listed in the Assessment Report Reg. No. 904/70/10/BT/IZ/E from 22th June 2010.
6. Validity Conditions
 - The certificate shall only promote its holder, the product and production places mentioned therein.
 - The transmission of this certificate to third parties is inadmissible as well as its use by third parties.
 - TÜV SÜD Czech shall be immediately notified about any product modifications compared to the certified specimen. This fact may cause the certificate continuation dependent on an additional conformity evaluation.
 - TÜV SÜD Czech shall supervise the proper functioning of the Quality System at the manufacturer within in twelve month on the basis of a concluded contract about the controlling activity.
 - The certificate shall apply for the period of 5 years from the date of its issue and can be renewed on demand.
 - The certificate shall only be reproduced complete including all annexes.
 - The right to use trademark TÜV SÜD Czech was not established to the certificate.
 - The certificate holder commits to keep records of all relevant complaints concerning the conformity of the products with the requirements of regulations and standards and make those records available to the certification body TÜV SÜD Czech.
 - Not specified items (advertising, use of trademark and certificates) are governed by the General Conditions for Product Certification, as amended.

